

REQUEST FOR INFORMATION NO. 2

ISSUED: February 29, 2016

**RE: Request for Qualifications-Request for Proposals
For Engineering Services for France Street Culvert Replacement
Town Bid No. 2016-002**

**FROM: Town of Rocky Hill, Engineering Dept.
761 Old Main Street
Rocky Hill, CT 06067**

TO: Prospective Bidders

This Request for Information (RFI) forms a part of the Proposal Documents and modifies the original Proposal Document dated February 10, 2016 as noted below. Acknowledge receipt of this RFI by signing the bottom and including it with the Proposal. Failure to do so may subject the Bidder to disqualification.

Question 1: Explain the road widening.

Answer 1: The roadway at the existing culvert is approximately 24' wide. The design should include the widening of the road to accommodate a 30' paved road, 5' snow shelf and 4' walk. The road shall be a consistent 30' at the approaches and to meet existing 30' wide roadway. A survey will be required to determining the limits of widening.

Question 2: Explain the limit of survey?

Answer 2: This is the area the town anticipates will require survey to determine the right of way and limits of construction. The town **does** require the survey locate the right of way from Sunset Ridge west to the culvert on the south side of France Street.

Question 3: Will there be a change in geometry of the France St and intersecting side roads?

Answer 3: This will be up to the consultant to determine as part of the design. The town does not anticipate intersection realignments.

Question 4: Are borings required?

Answer 4: The town does not anticipate borings will be required.

Question 5: Are as-built drawings required?

Answer 5: Yes, the town will require as-built drawings showing the location and invert of the structure, the centerline, edge of pavement, sidewalk and other surface features horizontal and vertically within the limits of construction.

Question 6: Is the consultant to perform inspection of the construction?

Answer 6: The town anticipates performing the inspection with town forces depending on work load. If inspection is required, a price would be negotiated.

Question 7: Who will move the utilities and who will pay for the moves?

Answer 7: It will be the towns responsibility.

END OF R.F.I. NO. 2

I acknowledge I/we are in receipt of this RFI

Signature: _____

Date: _____

Name of company: _____